

**GMCH.EX3940  
Residential Range Top Extinguisher Units**[Page Bottom](#)**Residential Range Top Extinguisher Units**[See General Information for Residential Range Top Extinguisher Units](#)**TWENTY FIRST CENTURY INTERNATIONAL FIRE EQUIPMENT & SERVICES CORP**

EX3940

3249 W STORY RD  
IRVING, TX 75038 USA

Models 2861-S, 2861-SH, 4 1/2 lb capacity, stored-pressure type dry chemical automatic extinguisher unit designed to discharge ordinary steartated sodium bicarbonate base dry chemical from fixed nozzles for extinguishment of fires occurring on conventional residential gas or electric range tops, not exceeding 36 inches in width, which are ventilated by a under-the-cabinet exhaust hood. These units are intended for use in ambient temperatures between +32 F and +120 F.

The Model 2861-S has demonstrated the capability of operating automatically within 90 s after autoignition of a 10 in. diameter cooking vessel when installed in accordance with the limitations outlined in the installation manual.

A description the Models 2861-S and 2861-SH extinguisher units along with their design and installation limitations is contained in the installation manual (p/n 51240) dated September 1989 and subsequent addendums; (p/n 51240-1) dated January 1990, (p/n 51240-2) dated February 1990, (p/n 51240-3) dated June 1990, (p/n 51240-4 for Model 2861-SH only) dated October 1990 and (p/n 51240-5) dated September 1991. Copies of these manuals are available from the Listee.

Models 1384-A and 1384-ASH, 2-1/2 lb. capacity, stored pressure type, wet chemical automatic extinguisher units designed to discharge wet chemical solution from fixed nozzles for the extinguishment of fires occurring on conventional residential gas or electric range tops, not exceeding 36 in. width, which are ventilated by a under-the-cabinet exhaust hood. These units are intended for use in ambient temperatures between +32 F and +120 F.

The Model 1384-A and 1384-ASH extinguisher units have demonstrated the capability of operating automatically within 90 s after autoignition of a 10 in. diameter cooking vessel when installed in accordance with the manufacturer's installation manual.

A description of the Model 1384-A and 1384-ASH extinguisher units along with their design and installation limitations are contained in the installation manual (p/n 71758-S) dated September 1989 (revised August 2000), and addendum (p/n 71757-1) dated August 2000. A copy of these manuals are available from the Listee.

Model G300, 5 lb. capacity, stored pressure type, wet chemical automatic extinguisher unit designed to discharge wet chemical solution from fixed nozzles for the extinguishment of fires occurring on conventional residential gas or electric range tops not exceeding 36 in. width (gas) or 42 in. width (electric), which are ventilated by a under-the-cabinet exhaust hood. These units are intended for use in ambient temperatures between +32 F to +120 F.

A description of the Model G300 extinguisher unit along with its design and installation limitations is contained in the installation manual (p/n G310A) dated July, 1995, and addendum (p/n G310A-1) dated August 2001. A copy of these manuals is available from the Listee.

Model G300A, 5 lb. capacity, stored pressure type, wet chemical automatic extinguisher unit designed to discharge wet chemical solution from fixed nozzles for the extinguishment of fires occurring on conventional residential gas or electric range tops not exceeding 36 in. width (gas) or 42 in. width (electric), which are ventilated by a under-the-cabinet exhaust hood. These units are intended for use in ambient temperatures between +32 F to +120 F.

A description of the Model G300A extinguisher unit along with its design and installation limitations is contained in

the installation manual (p/n G310A-A) dated February 20, 2007. A copy of this manual is available from the Listee.

[Last Updated](#) on 2007-05-23

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2007 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions:  
1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2007 Underwriters Laboratories Inc.®"

[Copyright © 2007 Underwriters Laboratories Inc.](#)